



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-6th Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4242

RFB-2020-24

**HIGHBRIDGE ROAD & EAST CAMPBELL ROAD PAVEMENT
REHABILITATION & SIDEWALK RECONSTRUCTION/EXTENSION**

ADDENDUM #1

May 27, 2020

**TOWN OF ROTTERDAM
SCHENECTADY COUNTY, NEW YORK
May 27, 2020**

**AMENDMENT NO. 1 TO:
CONTRACT NO. D036042**

SCHENECTADY COUNTY

PIN 1760.44

FOR THE LETTING OF

JUNE 5, 2020

**NOTICE TO PROSPECTIVE BIDDERS
CONTRACT PLANS, SPECIFICATIONS AND ESTIMATE**

1. Clarification to Item 662.17000108 Utility Hanger System:

The current specification for Item 662.17000108 states that the utility owner ("Company") will furnish the hangers and/or rollers required to hang the conduit. Please be advised that the following modifications apply to Item 662.17000108 – Utility Hanger System:

- The Contractor shall provide a design for the hanger system proposed to hang the 2" zinc coated steel conduit.
- The Contractor shall submit stamped shop drawings for review and approval prior installation.
- The Contractor shall furnish all materials necessary to install the conduit at the location identified on Dwg. No. TSD-02.
- The conduit owner is NYSDOT. NYSDOT will not furnish an inspector to oversee the work.

There are no existing fixtures on the girder.

PLEASE BE GOVERNED ACCORDINGLY WHEN SUBMITTING BIDS

END OF ADDENDUM #1