



Schenectady County  
Purchasing Department

620 State St.-6<sup>th</sup> Floor  
Schenectady, NY 12305  
[Purchasing@schenectadycounty.com](mailto:Purchasing@schenectadycounty.com)  
518.388.4242

**RFB-2021-37**  
Jail Boiler Replacement  
**ADDENDUM #5**

**June 21, 2021**


The purpose of this addendum is to provide detailed information to all Bidders. This Addendum is hereby included in and made part of the Contract Documents, whether attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

**Question 1:**

Can someone please describe in depth what work is expected from page M101 note #3 in terms of widening the drainage opening to sump pump area.

**Answer 1:**

There is a narrow opening to be widened in a concrete curb, and a small area to be cleaned of debris, see attached photos.



Please reach out to [Purchasing@SchenectadyCounty.com](mailto:Purchasing@SchenectadyCounty.com) with any questions.

**End of Addendum #5**