



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4240

RFB-2023-50
COUNTY OFFICE BUILDING EXTERIOR SIGNAGE

ADDENDUM #3

Issued Date 7/20/23

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

CONTENTS/RESPONSE TO QUESTIONS/REFERENCE TO ATTACHMENTS

Please acknowledge this addendum on your bid form.

1. Is the county bringing power to the sign locations? Are we making final connections or is the county doing so? **County will bring power to the sign. Sign company to make final connections.**
2. Can we make the monument signs a few inches deeper than the specified 7.75"? Upon review the signs will have 4" posts inside them so making them a bit deeper could be beneficial. **Yes.**
3. On the freestanding signs is the address pushed through and lit or is that applied in vinyl? **Pushed through and lit.**
4. Can we park our crane on the sidewalk for the wall signs? **Yes, but plywood must be put in place to protect the sidewalk.**
5. Will we need to get sidewalk barricade permits with the city? Since you are the governments specifically what permits are necessary and who is responsible for pulling the required permits? **No permit required for signs or sidewalk barricade, sidewalk barricades no longer than 1 working day.**

END OF ADDENDUM #3