



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4240

RFB-2023-63
SCHENECTADY COUNTY COURTHOUSE COLUMN REPAIR

ADDENDUM #1

Date: 2/8/2023

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

The following documents is hereby included in the documents posted on Bidnet and provided to plan holders:

Question: In lieu of welding the brick ties to the existing steel column, could powder actuated fasteners be used as an alternative to fasten the ties?

Answer: Yes, 0.157" diameter or larger powder actuated fasteners can be used to connect the brick ties to the existing steel column. Proposed PAF shop drawing/cutsheet shall be submitted during construction phase.

Please acknowledge this addendum on your bid form.

END OF ADDENDUM #1