



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4240

RFB-2023-64R

SCHENECTADY COUNTY PUBLIC COURTHOUSE CONDENSATE DRAIN REHABILITATION

ADDENDUM #2

Issued Date: 12/14/23

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

The following documents is hereby included in the documents posted on Bidnet and provided to plan holders:

CONTENTS/RESPONSE TO QUESTIONS/REFERENCE TO ATTACHMENTS:

General Bid RFI's

1. Q: The bidder is instructed to firestop at rated walls and floors. Detail #1 shows a existing penetration under each unit that power, dual temp lines, and condensate lines run thru. Are we to figure installing a firestop collar for PVC pipe at each location? If so how will we attach it to the slab to fulfill the UL detail if the rest of the hole is open and not fire stopped? Is the floor fire rated?
 - a. Response: Maintain existing fire ratings when routing through walls or floors. Provide firestop per Specification Section 221010 Article 2.12 for any new penetrations.
2. Q: What walls should we consider fire rated and what rating?
 - a. Response: Assume 1 hour rating for walls and floors.
3. Q: For the alternate I am assuming that the ceiling work needs to be done by a GC with a apprentice program? There is no budget listed in the drawing set so not sure if the project is over 200k.
 - a. Response: Alternate #1 is in the bidder's scope of work, per notes on drawings P101 through P103.
4. Q: Per the spec PVC isn't allowed in the plenums Can we get a clarification on the locations of the return air plenums since we don't have a mechanical plan for reference?



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4240

-
- a. Response: No plenums were found during site work. Notify the Engineer if condensate piping needs to be routed through a plenum.
5. Q: Can you let us know what kind of ceiling tile to price for the Alternate?
- a. Response: See product description below.

High Sound-Absorption & Blocking Tiles for Privacy



High sound-absorption and blocking tiles allow for privacy by reducing noise levels within a room and blocking sound from traveling between adjacent rooms that share a plenum space. These ceiling tiles have high NRC (Noise Reduction Coefficient) and CAC (Ceiling Attenuation Class) ratings to increase acoustical performance in high-traffic or large open spaces commonly found in offices, schools, and healthcare facilities.

- Brand: ARMSTRONG

Angled Tegular Edge for 15/16 in Grid

24 in x 24 in

↑Manufacturer Part Number	Texture	Sound Absorption (NRC)	Sound Blocking (CAC)	Fire Performance	Light Reflectance
1820A	Medium	0.7	35	Fire Resistive	85 %

Please acknowledge this addendum on your bid form.

END OF ADDENDUM #2