



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
purchasing@schenectadycountyny.gov
518.388.4240

RFB-2024-18

Old River Road (C.R.1) Over Tributary to Mohawk River Culvert Replacement

ADDENDUM #1

Date: 05/13/2024

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

The following documents is hereby included in the documents posted on Bidnet and provided to plan holders:

**CONTENTS/ RESPONSE TO QUESTIONS/ REFERENCE TO ATTACHMENTS
TO ALL HOLDERS OF THE CONTRACT DOCUMENTS:**

This Addendum is part of the Contract Bid Documents in accordance with the Notice to Bidders

1. Reference: Contract Bid Documents, Page 102, Special Note #1, Section 102-06, Bid Bond

There is no specific County issued template for the bid bond. The bid bond format can be an AIA form, or other.

2. Reference: Contract Drawings, Sheet ST-6 and others, Configuration of Bottom of Culvert Slab

The bottom slab of the precast culvert can be flat (no low flow dish, no "v-shaped" bottom) as long as the bed retention sills are cast in a "v-shape"

3. Reference: Contract Drawings, Sheet WL-1, Pressure Testing of New Water Mains

Q: What is the plan on pressure testing the newly installed waterline?

A: The new waterline shall be capped at the ends, pressure tested, then connected to the existing with the solid sleeve connections.



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
purchasing@schenectadycountyny.gov
518.388.4240

Company Name of Contract Document Holder

Signature Acknowledgment of Contract Document Holder

Date

RETURN WITH SIGNATURE ACKNOWLEDGEMENT TO TAMMY SAVINO BY E-MAIL: tsavino@bartonandloguidice.com

Please acknowledge this addendum on your bid form.

END OF ADDENDUM #1