



Schenectady County  
Purchasing Department  
**ADDENDUM**

620 State St.-2nd Floor  
Schenectady, NY 12305  
[purchasing@schenectadycountyny.gov](mailto:purchasing@schenectadycountyny.gov)  
518.388.4240

---

**RFB-2024-49**  
**NEW FUSELAGE TRAINER CONCRETE PAD AT THE SCHENECTADY COUNTY**  
**AIRPORT**

**ADDENDUM #1**

Date: 07/08/2024

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

The following documents is hereby included in the documents posted on Bidnet and provided to plan holders:

CONTENTS/ RESPONSE TO QUESTIONS/ REFERENCE TO ATTACHMENTS

**General RFI's:**

1. **Question 1: is there design PSI amount for the concrete to be designed for?**
  - a. **The concrete shall conform to the P-501 mix design with a 5000 PSI min.**
2. **Question 2: The project doesn't include subbase work?**
  - a. **The Subbase is installed by the County, the bid will not include P-209 or P-154 items (see attached photo).**



Schenectady County  
Purchasing Department  
**ADDENDUM**

620 State St.-2nd Floor  
Schenectady, NY 12305  
[purchasing@schenectadycountyny.gov](mailto:purchasing@schenectadycountyny.gov)  
518.388.4240



**Please acknowledge this addendum on your bid form.**

**END OF ADDENDUM #1**

