



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
purchasing@schenectadycountyny.gov
518.388.4240

RFB-2025-25
SUNY SCCC CST BUILDING LOBBY AND BATHROOM RENOVATIONS –
HVAC CONTRACT
C2 DESIGN GROUP

ADDENDUM #1

Date: 02/26/2025

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

The following documents is hereby included in the documents posted on Bidnet and provided to plan holders:

CONTENTS/ RESPONSE TO QUESTIONS/ REFERENCE TO ATTACHMENTS

General Bid RFI's:

1. In the Specs it calls for MC to carry all temperature control systems complete. I have reach out to many temperature control contractors and they say not enough info to quote. Please advise. Also says MC to carry temp heat. Is temp heat going to be needed for this project?
 - a. **Answer: Include radiant panel and convector controls as part of the mechanical bid as shown on drawing M601. Exhaust fans will be controlled form the light switch by the electrician. Temporary heat to be per Spec. Section 2300505-1, part 1.6, and is the responsibility of the mechanical contractor if required.**

Please acknowledge this addendum on your bid form.

END OF ADDENDUM #1